

N18

DEPARTMENT OF THE ARMY
HEADQUARTERS US ARMY TRAINING CENTER, INFANTRY, AND FORT DIX
Fort Dix, New Jersey 08640

REGULATION
NUMBER 420-13

17 January 1972

REPAIRS AND UTILITIES

REPLACEMENT OF ELECTRIC LIGHT BULBS

1. PURPOSE: This regulation outlines the procedures for replacement of electric light bulbs and prescribes the correct wattage of light bulbs to be used in various areas throughout the installation.

2. RESPONSIBILITIES:

a. Replacement of burned-out fluorescent tubes and starters will be accomplished by Facilities Engineering personnel or by personnel possessing certificates issued by the Facilities Engineer.

b. Commanders will procure light bulbs through their own Utilities Facility. Individuals in the using activity will obtain light bulbs from the Facilities Engineer Warehouse, Bldg 5133, upon submission of DD Form 3161.

c. Quarters occupants may obtain light bulbs from the Family Housing Self-Help Store located in Building 5170.

d. In the event lighting is considered inadequate, requests to improve candle power will be submitted on DA Form 2701 in accordance with FDR 420-10.

3. CORRECT WATTAGE TO BE USED IN BUILDINGS: Following is the correct wattage of light bulbs to be used in buildings throughout the post:

<u>LOCATION</u>	<u>AUTHORIZED WATTAGE</u>
Exterior lighting (entrance and exit)	25
Heater room (boiler room)	100
Latrine (toilet)	60
Corridor (hall)	50
Stairwell	100
Kitchen area	100

This regulation supersedes Regulation 420-13, this Headquarters, 15 March 1967, subject: Replacement of Electric Light Bulbs.